



GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT  
NO OBJECTION CERTIFICATE FOR OCCUPANCY



**FIRE AND EMERGENCY SERVICES CERTIFICATE**

**From**  
The District Fire Officer,  
O/o. Fire & Emergency Dept.  
Hyderabad Dist

**To**  
The Secretary,  
Azan International School,  
Tolichowki, Hyderabad-TS

Rc.No.4390/A1/502/2024 Dt. 22-04-2024

**Sub:** Fire and Emergency Services Department – Central Region, Hyderabad District –T.S. Fire safety measures to non multi storied building (Educational Institute) Azan International School, H.No.9-4-136, Seven Tombs, Tolichowki, Hyderabad – issue of certificate for one year from the date of issue – Reg.

- Ref:**
1. Section 12(2) of Fire service Act, 1999 and rule 15(2) of TS Fire and Emergency operations and Levy of Fee rules 2006 .
  2. Chief office Proc RC No.3205/2021 dated 09-10-2021.
  3. Inspection dated 27-03-2024.
  4. Application dated 09-01-2024 Secretary, Azan International School, H.No.9-4-136, Tolichowki, Hyderabad

\*\*\*

In obedience to the instructions issued by the Director of Fire Services, TS Hyderabad vide reference 2<sup>nd</sup> cited, and in compliance to the authorization given in accordance with vide reference 2<sup>nd</sup> cited, as per the recommendation of Inspection reported submitted vide reference 3<sup>rd</sup>, the fire safety measures to the non-multistoried building with height of 24 ft. for Educational building with ground floor + 4 floors-Azan International School, H.No.9-4-136, Seven Tombs, Tolichowki, Hyderabad District - TS are furnished here under:

Particulars of building as follows:

- a) Institution Name & Address: Azan International School, H.No. 9-4-136, ToliChowki, Hyderabad
- b) Area of plot of building: 2006.7 Sq.Mtrs
- c) No. of blocks Floors: one Lower Ground + Ground + 4 floors.
- d) Floor wise details:

(Contd..2)



Sl.No.	Floor	Area in Sq.Mts	Occupancy (Educational/Hostel/Dormitory)	Occupant load
1	Lower ground	334.45	Educational	-
2	Ground + 4 floors	1672.25	Educational	120 (I-IV-vacant)
3	Total	2006.70		

2. The Management has provided the following safety measures:

- Terrace Tank 15,000 liters capacity is provided and Booster pump 450 LPM.
- One internal stair case width 2.70 mts provided.
- Two external staircase width of 1.25 mts each provided.
- Every room with a capacity of 50 students and above shall have at least doorways.

3. The following fire fighting's systems are suggested:

- (3) Three 12 Ltrs water expelling extinguishers.
- (4) Four CO2 extinguisher of each 4.5 kg capacity- for each floor.
- (10) Ten DCP extinguishers of each 5 kg capacity.
- 4 buckets 9 Ltrs round bottom fire buckets for each floor (2 buckets filled with water and two filled with sand) for every 600 sq.mtrs built up area/floor should be hang to a stand.
- For every 600 sq.mtrs built up area/floor, the fire extinguishers should be located as to be available within 25 mtrs radius.

4. The following No Objection Certificate issued for a period of one year from the date of issue subject to the following conditions:

- All Fire safety measures as advised should be provided without fail.
- No temporary structure such as tents or thatched construction shall be allowed for education institutions.
- All the staff / watch and ward staff train in first aid fighting.

5. The management may be informed of the following rules and regulation:

- As per clause 13.1 of part II of, the National Building code of India neither granting of the permit nor the approval of the drawings and specifications made by the authority during erection of the building shall in any way relieve the owner of such building from full responsibility for carrying out of the work in accordance with the requirements of the National Building Code of India.

(Contd..3)

ii) As per clause 9.3 of part II of the National Building Code of India "The licensed Architect/Engineer/structural engineer/Supervisor/Town planner be responsible for supervision of the construction for the completion certificates. In the event of violation of the provisions of the code be shall be liable to penalties as prescribed by the authority including cancellation of the license.

6. The management may advised to installation of above fire measures and keep all Fire safety measures in good working conditions at all times.

  
District Fire Officer  
Hyderabad - Dist  
**DISTRICT FIRE OFFICER**  
**HYDERABAD - T.S.**



Copy submitted to Director General of Fire and Emergency services. Hyd.

Copy submitted to the Regional Fire Officer, Hyderabad.

Copy to Deputy Commissioner, GHMC concerned.